



No connections permitted between R/W control valve and meter.

Meter Setter shall be installed as shown above.

There shall be no more than one piping bend before the Meter Setter.

Meter Setter shall be securely supported to the floor or a lateral wall.

Meter Setter shall be installed within 1' of the service entrance to the building and a minimum of 12" from any lateral obstruction.

CITY OF COLUMBUS
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF WATER

APPROVED:

ENGINEER

Geff Mulland

4/1/01
DATE

STANDARD DETAIL

1 1/2" METER SETTING

L-6317D